POWER ENGINEERING CO., INC.
Salt Lake City, Utah 801-532-6972

Canyons School District

School: ____________________

Water Treatment Log

Date	Cooling Tower Tests				Closed Systems Chilled Water		Pump Settings				Treatment Added	Comments
	Water Meter	Conductivity	pH	OTT	8410 Nitrite	% Glycol	Tower Treatment		Biocide			
					800-1000	30-40%	Stroke	Speed	Stroke	Speed		